

UTILITY CROSSING N.T.S.

- LENGTH OF EXTENSION OF PIPE AND HARNESS RODS SHALL BE IN ACCORDANCE WITH THESE ENGINEERING STANDARDS.
- 2.) ALL WATER MAINS TWELVE (12") INCHES OR SMALLER, WHICH CROSS UNDER DISTRICT CONDUITS SHALL BE DUCTILE IRON.
- 3.) A BORED CROSSING MAY BE REQUIRED BY THE ENGINEER.

A Delay
5 100 5-
A
COUNTY
-

STANDARDS & SPECIFICATIONS

REVISED:

UTILITY CROSSING

DATE: DRAWING NO. 200-37